

ACCESSORY KIT INSTALLATION INSTRUCTIONS

COIL GUARD ACCESSORY MODEL 1CG0401

FOR MODELS D*CE/D*CG036-076, D*HB/D*UC036-060, DEE/DHE/DHG 036-060

SINGLE PACKAGE AIR CONDITIONERS

& B*CH/B*CB036-60 & B*HN/B*DF036-60 HEAT PUMPS

GENERAL

This instruction provides the necessary information to field install an outdoor coil guard accessory on the single package units indicated above.

This accessory will provide protection for the fins and tubes on the entire exposed surfaces of the outdoor coil. The kit contains 3 vinyl coated wire grids, in three different size widths (small, medium and large) - all are the same size in length. Refer to Figure ?.

The 2, 5, and 6 ton units require all three grids for complete coil protection, however - on 3 ton units, the width of the small grid (1) only must be trimmed to suit. The 4 ton units require the medium (B) and large (C) grids only. The small grid (A) may be discarded on 4 ton units.

INSTALLATION

Install the coil guard grids on all exposed surfaces of the outdoor coil per the following procedure:

1. Each grid must be positioned so that it will rest inside of the pan flange at the bottom of the coil and inside of the cover flange at the top of the unit.

Vertical wires on the grids should be facing toward the coil as shown in Figure ?.

2. Grids may be installed in either of the following two methods:

- a. Bend outward at the center of each grid (from top to bottom) and place into position behind the flanges described above, or
- b. Place the top of each grid behind the unit cover flange, lift up press bottom of grid behind the pan flange and allow it to slide down into its final position.

NOTE: Wherever a unit panel is attached to the coil endsheet, the screws must be loosened or removed to relieve the coil clearances at the pan flange to allow grid to slip into position. Replace and tighten all screws after grids are in place.

3. The width of grid (A) on 3 ton units only must be trimmed to suit the width of the front coil surface. Trim to the desired width by uniformly cutting through all the horizontal bars.




FIGURE 1 - COIL GUARD ACCESSORY INSTALLATION

Subject to change without notice. Printed in U.S.A.

Copyright © by Unitary Products Group 2000. All rights reserved.

Supersedes: 530.18-N1.8V (287)

035-07388-000 Rev.A (0501)

**Unitary
Product
Group**

**5005
York
Drive**

**Norman
OK
73069**