

ACCESSORY KIT INSTALLATION INSTRUCTIONS

Transformer Kit - 2EC06700124

FOR SINGLE PACKAGE AIR CONDITIONERS AND HEAT PUMPS

GENERAL

This kit is to be used for single phase small package units with economizers to convert from a 40VA transformer to a 75 VA transformer.

CONTENTS OF KIT

| ITEM | QTY. | PART NUMBER | DESCRIPTION |
|------|------|-------------|----------------------|
| 1 | 1 | 17634 | Transformer 75 VA |
| 2 | 1 | 10844 | Instructions |

TOOLS REQUIRED FOR INSTALLATION

A hex nut driver 5/16" is the only tool needed to install this kit. This tool is not supplied with this kit and must be supplied at time of installation.

INSTALLATION

WARNING

Disconnect power to the unit. Failure to disconnect the power supply could result in electrical shock.

1. Use the 5/16 inch nut driver to remove the control access panel from the front of the unit.
2. Disconnect all the wires attached to the 40VA transformer. These wires will be reconnected later to the appropriate terminals on the 75VA transformer.
3. Use the 5/16 inch nut driver to remove the two screws securing the 40VA transformer and remove it.
4. Use the screws removed in step 3 to secure the 75VA transformer. Make sure the ground wire(s) are connected to one of the screws.
5. Reconnect the wires to the appropriate location on the 75VA transformer. Be sure to choose the correct voltage input on the transformer primary. Cap the unused terminal on the transformer.
6. Remove the white wires from the 40VA transformer and install on the open terminal on the 75VA transformer.
7. Restore the power supply to the unit and verify proper operation.
8. Replace the control access panel.

