

**Product certification statement:**

**FOR MODELS: DNQ, DNX, DNY, DNZ, DNP, DNH, DNA, DEQ, DEX, DEY, DEZ, DEM, DEH, DEB; DYQ, DPQ, DYX, DYY, DYZ, DYP, DYH, DYA, DPX, DPY, DPZ, DPM, DPH, DPB, AND ACP-13 1-5 TON COOLING SERIES. ALSO INCLUDES BHX, BHZ, BHP, BHH, BHA; BUX, BUZ, BUP, BUH, BUA, HPP-13, BHQ, AND BUQ 1.5-5 TON HEAT PUMP SERIES.**


**PRODUCT & MOUNTING CERTIFICATION**

I have reviewed the specified unit cabinet and panels' test data results, installation instructions, and the contents of the Hurricane Curb and Wind Kit, and the On-grade Kits (MicroMetl Numbers #0557DNZ2460CR07WN18, #CRB557WND07KIT18, and York UPG #1HK0450) for use with the unit model listed above, and have made the following findings:

The specified units and their special Roof Curbs will resist a 150 MPH wind speed when the unit is fastened per the curb installation instructions. The four (4) micro hold supports, one per side, must be installed on all applications. Micro holds must also be fastened inside the roof curbs, before the unit is set.

The specified units and their On-Grade mounting kits allow the designated units to resist a 150 MPH wind speed when fastened to 2,500 psi minimum test concrete pad in accordance with the instructions provided. Acceptable anchorage fasteners are six (6) WW- 3850 Red-Head Tru-Bolt IBC rated concrete anchors , S/S-304, 3/8"-16 NC x 5" (short angle brackets), one through each short bracket. Minimum pad slab thickness shall be 5" and the minimum embedded depths shall be 2-5/8" for the 3/8" diameter anchors. Minimum center line spacing of anchors shall be at 5-1/4", which is far exceeded per the recommended installation layout. Minimum edge distance shall be greater than 1-1/2". The four (4) self drillers per anchor are #12 stainless steel 1-1/4" long or equivalent screws.

My technical study was based upon the 2006 edition with 2008 addendums of ASCE 7-05, the Florida Building Code and IBC, 3 second gust wind speed, exposure category "C", mounting heights from ground level up to 500 feet, and using an importance factor of 1.15.



John D. Buerosse  
Florida P.E. 0050867  
750 E. Sample Rd.  
Bldg. 3 • Suite #220  
Pompano Beach, FL 33064  
954-633-4693